

Annexure I

Scope of work:

1. Dismantling of wooden boarding in lining of walls and partitions of the identified showcases including stacking in segregation of serviceable and unserviceable materials within 50 meters lead.
2. Treatment of existing masonry using chemical emulsion @ one litre per hole at 300 mm interval including drilling holes at 45 degree and plugging them with cement mortar 1:2 (1 cement : 2 coarse sand) to the full depth of the hole : With Chlorpyriphos/Lindane E.C. 20% with 1% concentration
3. Providing & Applying polymer modified, flexible cementitious negative side waterproofing coating with elastic waterproofing polymers on interior wall plaster surface in three coats @14.35 kg /10 sqm. one coat of self-priming of cementitious waterproofing polymer(dilution with water in the ratio of 1:1) and two coats of cementitious waterproofing polymer (dilution with water in the ratio of 3:1) after scrapping and properly cleaning the surface to remove pre-existing paint film & loose particles till plaster is visible, complete in all respect as per the direction of Engineer-in-Charge.
4. Providing and fixing of 2 Nos of showcases measuring 6' x 5'x 2' (H x W x D) using 19mm thick factory pressed BWP grade marine ply as per IS 710 of approved brand marine ply in all internal partitions and shelves/racks with grit wash finish to match the color and finish of adjoining showcases. The fascia shall be made with first class teak wood finishes to match existing showcase complete with all necessary installation accessories, locking arrangement etc. as per the direction of engineer- in charge.

Site Location: Assam State Museum, GNB Road, Ambari Guwahati

Project Duration: 3 weeks

Site Photographs: Below are few images from the site. However the bidders are urged to visit site during office hours (except Mondays and government holidays) for better understanding.



Figure 1 Front View of the Showcase




Figure 2: Internal finish (grit wash)